


METER SIZE	BOX DIAMETER	D&L RING & COVER, OAE	FORD SETTER, OAE
1"	18"	L-2241	VBHC 74-18W-44-44-G or Q
1 1/2"	24"	B-5074	VBHH 76-18-44-66-G or Q
2"	30"	B-5076	VBHH 77-18-44-77-G or Q

A
VAR CONNECTION DETAIL PLAN
SCALE: N.T.S.



NOTES:

1. 3/4" LATERAL ALLOWED ONLY BY APPROVAL OF THE DISTRICT ENGINEER
2. ON TWIN HOME LOTS THE WATER METERS SHALL BE TEED OFF A COMMON 1-1/2" MIN. LATERAL COMING FROM THE MAIN AND PLACED ON EACH SIDE THE LOT DIVIDING LINE ACCORDING TO THE LAYOUT OF THE HOMES.

METER BOX HDP A.D.S. N-12 (O.A.E.)
CORRUGATED POLYETHYLENE PIPE CORRUGATED
EXTERIOR/ SMOOTH INTERIOR (SEE TABLE)
WHITE INSIDE COLOR, BOX TO BE A CONTINUOUS
PIECE OF PIPE WITH NO EXTENSIONS.

B
VAR CONNECTION DETAIL SECTION
SCALE: N.T.S.

PROJECT # DATE
SU1037 12/13/16

W-05

FILE:

CENTRAL IRON COUNTY WCD
STANDARD DETAILS
1"-2" WATER METER
IRON COUNTY, UTAH



CICWCD
88 E Fiddlers Canyon Road, Suite A
Cedar City, UT 84721
Phone: 435.865.9901
Fax: 435.865.9902